



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

No detailed internal inspection of flues (Integrity, Constructions and Lining) has been carried out

Certificate Reference

Brighter Living 0002

Certificate No:0002

Engineers Details

Trading Title:

Address:

Post Code:

Gas Safe No:

Telephone No:

Installation Details

Installation Address:

Post Code:

Telephone No:

Client Details

Client Address:

Post Code:

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading	CO Reading	FlueType (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Combi boiler	Ideal	LOGIC + COMBI	NA	NA	RS	YES	0.0005	YES	30 kw	YES	YES	YES	N/A	NO	YES
2																	
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve accessible:

Gas Tightness Satisfactory:

Gas Installation Pipework Visual Inspection Satisfactory:

Number Of Appliances Tested:

Equipotential Bonding:

NEXT INSPECTION DUE ON OR BEFORE:

Installation Pass:

CO Alarm fitted and working?

Smoke alarm fitted and working?

Signatures

Report Issued By:

Name:

Signed:

Date:

Report Received By:

Name:

Signed:

Date:

Gas ID Number: